

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20183647  
Address: 1401 NW VIEW HIGH DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Erosion Sediment Control (ESC) Inspection</b>	John Jackson	Partial	Wednesday, April 10, 2019

Corrective Action Required:

1	Contractor began prep for the laying of hay matting. on 4/10/19. Silt fence is still down throughout the job site. As per Casey Williams of Fogel- Anderson silt fencing will be reinstalled soon.
---	--

**Comments:**