

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170407
Address: 3560 SW HOLLYWOOD DR, Unit:6, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mike Copeland	Failed	Tuesday, April 16, 2019

Partial Correction:

1	THIRD FLOOR	NO VIOLATIONS-LIGHT WEIGHT CONCRETE AROUND TUBS APPROVE
---	-------------	---

Partial Correction:

2	SECOND FLOOR	NO VIOLATIONS-LIGHT WEIGHT CONCRETE AROUND TUBS APPROVE
---	--------------	---

Corrective Action Required:

3	FIRST FLOOR	1. South garage, south wall missing hold downs 2. Unit to the south of the southwest stair tower: missing strap top plate south wall, area next to the tub not firestopped, cut bottom chord of truss in the same area. 3. First floor draft stops not compliant. No compliant draft stops between garages/corridor. Multiple penetrations in unit draft stops. 4. North garage wall missing hold downs.
---	-------------	---

Comments: