

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20180217
Address: 1300 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Wednesday, April 17, 2019

Corrective Action Required:

1	Misc	-EXPOSE THE WATER METER -SECURE AC WHIP -RECEPTACLE LOCATED WITHIN SIX FT OF THE WET BAR SINK MUST BE GFCI-PROTECTED -PROVIDE AN INDIVIDUAL CIRCUIT TO THE HYDROTUB MOTOR RECEPTACLE
---	------	---

Comments: