



### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20173864	Date:	April 17, 2019
Project Title:	TPC INTERIORS	Applicant:	
Location:	1510 SE KINGSPPOINT DR, LEES SUMMIT, MO 64081	JAYHAWK FIRE & SAFETY 1138 KANSAS AVENUE KANSAS CITY, KS 66105	
Type of Work:			
Occupancy Group:	UC		
Description:	SHELL BUILDING FOR FUTURE OFFICE/WAREHOUSE	Primary: (913) 371-8494	
Construction Type:	Type IIB (Unprotected)		
Map Page:	195R		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Alarm Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:(information purposes)

Field testing and acceptance testing of the system will be required prior to the final occupancy inspection. Contact the fire department to schedule testing. (816)969-1300

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**