

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20183263  
Address: 829 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	John Borns	Partial	Wednesday, April 17, 2019

Partial Correction:

1	Misc	OK TO POUR WHEN READY WALL SPREAD FOOTING AT: ON D.5 FROM D.4 TO D.S + 4'; FOOTING STEPS AT D.K and D.L; CANTILEVERED SITE WALL FOOTING;  <b>PERIMETER TRENCH FOOTING COMPLETE; UFER GROUND JUMPERS IN PLACE AT SOUTH AND NORTH ENDS</b>
---	------	--

Partial Correction:

2	Misc	OK TO POUR WHEN READY FOOTING FOR RETAINING WALL BETWEEN BLDGS #2 & #3
---	------	--

**Comments:**