

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20190091  
Address: 316 SE DOUGLAS ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Water Line - Thrust Restraint</b>	Joe Starlin	Partial	Thursday, April 18, 2019

Informational:  
1 Misc 4-18-19 Scott poured thrust blocks, he needs to add two more one in front of the vault and one at the last fitting before the building.

**Comments:**