

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20182837
Address: 450 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Street - Surface Course	Ronald Paynter	Passed	Thursday, April 18, 2019

Informational:
1 Misc J&J Asphalt laid 1 1/2 inches of APWA-5 asphalt for the surface of the parking lot. The area between the ADA ramps is less than 2 percent cross slope.

Comments: