

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20181758  
Address: 2618 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Brandon Kalwei	Failed	Thursday, April 18, 2019

Corrective Action Required:

1	Misc	-tempered glass above master bath tub -hammer resister for laundry upstairs? -sheet rock underneath stairs in basement -final grade, splash blocks, final grade plot plan required
---	------	---

**Comments:**