

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20190091
Address: 316 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Thrust Restraint	Joe Starlin	Passed	Friday, April 19, 2019

Informational:
1 Misc 4-18-19 Scott poured thrust blocks, he needs to add two more one in front of the vault and one at the last fitting before the building.

Informational:
2 Misc 3-18-19 Scott poured the last two thrust blocks, I showed the pics of the thrust blocks to Bob Burns and talked with Steve Robbins about them. They both are good with them. Scott is now ready to flush the line.

Comments: