

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20180778  
Address: 1849 SW BLACKSTONE CT, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	John DiMauro	Passed	Friday, April 19, 2019

Informational:

1	Misc	The driveway approach has been formed and has 6" of rock that has been compacted. Steve Robbins 12/21/2018 4:12 PM
---	------	--

Corrective Action Required:

2	Misc	Driveway approach was already poured upon Inspector arrival. Inspector unable to inspect and verify subgrade standards.
---	------	---

**Comments:**