

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20180715
Address: 4825 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Monday, April 22, 2019

Corrective Action Required:

1	Misc	-ROCK UNDER GARAGE BOX-OUT WALL -SCREW THE REAR EXTERIOR DOOR EMBEDDED METAL BRACE INTO THE STUDS WITH MIN. 3" SCREWS -INSTALL MAXIMUM 30 AMP AC BREAKER -INSTALL WINDOW WELL LADDER
---	------	---

Comments: