

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183262
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Monday, April 22, 2019

Partial Correction:

1	Misc	OK TO POUR WHEN READY TWO ELEVATOR PIT SLABS
---	------	--

Partial Correction:

2	THE FOLLOWING AREAS ARE APPROVED	a.7/a.r to FOOTINGS AT LEFT WING: EAST ELEVATION FROM A.B TO NORTH ELEV.; NORTH ELEVATION APPROVED; WEST ELEVATION FROM NORTH TO A.N LINE; ON A.1 FROM A.B TO A.Q; FROM A.1/A.Q CW TO A.AX/A.6 WITH UFER GROUND JUMPER; A.7/A.AX CW ATO A.7/A.AG; A.7/A.R TO A.7/A.E;
---	----------------------------------	---

Partial Correction:

3	Misc	UFER GROUND: 1 OF 3 UFER APPROVED NORTH ELEVATION; UFER AND REMAINDER PERIMETER APPROVED TO POUR
---	------	--

Partial Correction:

4	Misc	OK TO POUR WHEN READY ISOLATED FOOTING AT A.1/A.Z
---	------	---

Comments: