## CITY OF LEE'S SUMMIT **Development Services Department** 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRPWFC20173801

Address: 3500 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date: Tuesday, April 23, 2019 **DE - Water Line - Coliform Test** Partial 1 Informational: We collected the day 1 samples for the 4"in domestic line and delivered

1 Misc

them to the lab. We will know the results in 24 hours.

Informational:

The day 1 test spot 1 sample taken on 4/17/2019 failed for total coliform. 2 Misc

The crew started the process over according to the flow chart last week and

flushed the line yesterday 4/22/2019

Today we collected the new day 1 samples for the 4" private domestic line

and delivered them to Keystone Labs.

Comments: