

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20190091
Address: 316 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|-------------|----------|------------------------|
| DE - Water Line - Thrust Restraint | Joe Starlin | Passed | Friday, April 19, 2019 |

Informational:
1 Misc 4-18-19 Scott poured thrust blocks, he needs to add two more one in front of the vault and one at the last fitting before the building.

Informational:
2 Misc 3-18-19 Scott poured the last two thrust blocks and is now ready to flush the line.

Comments: