

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183265
Address: 901 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Electrical Inspection - Commercial	John Borns	Passed	Wednesday, April 24, 2019

Comments: COPPER JUMPERS TO ABOVE T.O.S. FOUND TO BE CONNECTED TO RE-BAR UFER JUMPER FROM FOOTING RE-BAR -- ONE AT EACH END OF BUILDING. OK TO COVER WHEN READY.