CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063

(816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20182996

Address: 1410 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

DE - Water Line - Construction Joe Starlin Partial Wednesday, April 24,

Inspection 2019

Informational:

1 Misc Approximately 130 ft of PC 235 pipe has been installed . The crew has also

places tracer wire and adequate amount of gravel has been placed above and

below pipe.

Informational:

2 Misc 3-21-19 The crew, upon arrival, poured concrete kickers and thrust blocks on

all appropriate locations. The crew is continuing on water lines through out

today.

Informational:

3 Misc 3-21-19 The crew laid 84ft of water line.

Corrective Action Required:

4 Misc 3-26-19 The Beemer crew are getting ready to have Magnum Boring start

boarding to water line on Douglas.

Informational:

5 Misc 3-26-19 The crew have placed 100ft of water line and placed a hydrant.

Informational:

6 Misc 2-27-19 The Beemer crew have poured kickers and are starting to install more

water line.

Informational:

7 Misc 2-27-19 The Beemer crew have poured kickers and are starting to install more

water line.

Informational:

8 Misc 2-27-19 The Beemer crew have poured kickers and are starting to install more water line.

Informational:

9 Misc 3-27-19 The crew placed approximately 80ft of water line.

Informational:

10 Misc 3-28-19 The crew have placed both boxes for fire line, water line is all the

way across Douglas Road. They are back filling before rain sets in.

Informational:

11 Misc 3-28-19 The crew have placed both boxes for fire line, water line is all the

way across Douglas Road. They are back filling before rain sets in.

Informational:

12 Misc 4-1-19 The crew did 110ft west side of 90. 80ft north of 90. Water line.

Informational:

13 Misc 4-3-19 The crew have placed 160ft of water line and also ran water line from

the main to where the storage building will be.

Informational:

14 Misc 4-9-19 The Beemer crew have poured all trench checks and thrust blocks.

They are going to wet tap tomorrow 4-10-19

Informational:

15 Misc 4-11-19 All water line is in and the wet tap on Victoria is done.

Informational:

16 Misc 4-19-19 Winwater did the wet tap on Douglas and the Beemer crew will start

tying in the water line.

Informational:

17 Misc 4-24-19 The Beemer crew dechlorinated the entire water line. We will be

pulling samples 4-25-19.

Comments: