

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20183804
Address: 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Coliform Test 2	Ronald Paynter	Passed	Thursday, April 25, 2019

Informational:
1 Misc Met with Wes from Richards Construction. Pulled second sample from the water main for the second Bac-T test at 3:35 PM. Dropped sample off at Keystone Laboratories at 4:16 PM

Informational:
2 Misc Water line passed second Bac-T test performed by Keystone Laboratories.

Comments: