

ANALYTICAL REPORT

March 21, 2019

Work Order: 1C91327

Page 1 of 3

Report To
Ron Paynter City of Lee's Summit - Public Works Dept. 220 SE Green Street Lees Summit, MO 64063

Work Order Information
Date Received: 03/20/2019 11:49AM Collector: Paynter, Ron Phone: (816) 969-7428 PO Number: Routine Analysis

Project : Richards Construction Company Inc

Project Number: John Knox Astoria

Analyte	Result	MRL	Batch	Method	Analyst	Analyzed	Qualifier
1C91327-01	Water Main			Matrix:Drink Wtr		Collected: 03/20/19 11:00	
Total Coliforms	<1.0 MPN/100ml	1.0	1CC0780	9223B-QT	CLJ	03/20/19 16:15	
E. Coli	<1.0 MPN/100ml	1.0	1CC0780	9223B-QT	CLJ	03/20/19 16:15	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.

City of Lee's Summit - Public Works Dept.
220 SE Green Street
Lees Summit, MO 64063

March 21, 2019

Page 2 of 3

Work Order: 1C91327

Certified Analyses included in this Report

Method/Matrix	Analyte	Certifications
9223B-QT in Drink Wtr		
	Total Coliforms	KS-KC,MO-KC
	E. Coli	KS-KC,MO-KC

Code	Description	Number	Expires
KS-KC	Kansas Department of Health and Environment-KC	E-10110	04/30/2019
KS-NT	Kansas Department of Health and Environment (NELAP)	E-10287	10/31/2019
MO-KC	Missouri Department of Natural Resources	140	04/30/2019
SIA1X	Iowa Department of Natural Resources	95	02/01/2019

End of Report



Keystone Laboratories, Inc.

Carolyn Jackson
Project Manager

Keystone

PAGE: 1 of 1

BILL TO:

NAME: PERCUTANEOUS CONSTRUCTION

CO. NAME: _____

ADDRESS: T.O. 506 1707

CITY/ST/ZIP: FL MO 37120

PHONE: 810-224-7100

[illegible]

Remarks:

Received for Lab by: (Signature)

Time: 10