CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20172630

Address: 1337 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Khanh Nguyen Failed Thursday, April 25,

Residential 2019

Corrective Action Required:

1 Misc -Final grade, sod, splash blocks

-Notch deck posts and install deck beam to posts -Fix ground fault condition of rear gfci receptacle

-Seal exterior wall penetrations

-Secure AC whip

-Install tamper proof caps at AC coolant valve

-Install front light. Light fixture shall meet security code -Install CO&smoke alarm outside front bedroom

-Connect gas supply to cooktop

-Receptacle right side of cooktop-support receptacle yoke and provide gfci

protection

-Install security strike plate at deck door screwed to studs with 3" screws

-Support receptacle yokes at wet bar countertop

-Install breaker lock for oven, out-of-sight water heater

Comments: