

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183262
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Passed	Thursday, April 25, 2019

Comments: UNDER-SLAB CONDUIT AND BOXES AT CENTER SECTION OK TO COVER WHEN READY. UFER GROUND JUMPER CONNECION AT SE CORNER OF CENTER SECTION NEAR A.A.E/A.A.F.