

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20181851  
**Address:** 1531 SW BLACKSTONE PL, LEES SUMMIT, MO 64082  
**Inspected On:** Friday, April 26, 2019  
**Inspected By:** Jason McRoy  
**Expiration Date:** 5/26/2019 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Jason McRoy	Temporary C of O	Friday, April 26, 2019

**Corrective Action Required:**

2	Misc	1.THERE IS ASMALL SINK HOLE LOCATED IN THE FRONT YARD AT SOUTHEAST SIDE OF YARD CLOSE TO THE WATER METER. 2.THERE IS A LARGE SINK HOLE ON NORTHWEST SIDE OF FRONT YARD LEFT OF DRIVEWAY. 3. CONFIRM 6" OF FALL IN FIRST 10' IN BACK OF HOUSE.  PROVIDE BACKFLOW CERTIFICATION FOR IRRIGATION.
---	------	---