

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20180219
Address: 201 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Fire Line - Hydrostatic Test	Ronald Paynter	Partial	Monday, April 29, 2019

Informational:

1	PW-Misc	The hydrostatic pressure twst for the 4" service line has been passed. They are planning on possibly doing the fire line today.Steve Robbins 10/01/2018 9:51 AM
---	---------	---

Informational:

2	PW-Misc	The hydrostatic pressure test for fire line has passed 200psi for 2hrs. This is a partial completion of the water lines that have been installed.Steve Robbins 10/04/2018 7:54 AM
---	---------	---

Informational:

3	Misc	Hydrostatic pressure test of 8 inch fire line passed 200 PSI for over 2 hrs. Still need to test the 4 inch domestic line. RP 4/29/19
---	------	--

Comments: