

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20172630
Address: 1337 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Monday, April 29, 2019

Corrective Action Required:

1	Misc	**INSTALL SILT FENCE PER CITY REQUIREMENT, ESPECIALLY ALONG PROPERTY LINE
---	------	---

- Final grade, sod, splash blocks
- Notch deck posts and install deck beam to posts
- Seal exterior wall penetrations
- Install security strike plate at deck door screwed to studs with 3" screws

Comments: