

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181650
Address: 2525 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Failed	Monday, April 29, 2019

Corrective Action Required:

1 Misc

- Wall bracing loose and nailed over a 45° angel.

-Wall bracing at the boot bench is over 60°.
check wall bracing at sheetrock stage , provide plans at next inspection

Comments: