

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183233
Address: 1317 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Passed	Wednesday, May 01, 2019

Informational:
1 Misc

**THE LARGE ROOM IN THE BASEMENT IS TO BE UNFINISHED.
**ELECTRICIAN-PLEASE ONE NEUTRAL CONDUCTOR PER LUG HOLE. YOU CAN HAVE TWO EQUIPMENT GROUNDING CONDUCTORS (OR 3 DEPENDS ON PANEL) PER LUG, BUT NOT THE NEUTRAL CONDUCTORS
**OK TO ROCK

Comments: