

# Inspection Summary

Permit #: PRSITE20190091, Development - Site  
ARCADE ALLEY

Address: 316 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

## Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Coliform Test 1 Informational 1	Joe Starlin	Partial	Wednesday, May 01, 2019
4-29-19 We pulled a water sample and it has been delivered to the lab.			
DE - Water Line - Coliform Test 2 Informational 1	Joe Starlin	Partial	Wednesday, May 01, 2019
5-1-19 We pulled the second set of samples at 8:22am and they have been delivered to the lab.			
DE - Water Line - Coliform Test 1 Informational 1	Joe Starlin	Passed	Wednesday, May 01, 2019
4-29-19 We pulled a water sample and it has been delivered to the lab.			
Informational 2	Joe Starlin 05/01/2019 10:05 AM The lab results for coliform test 1 have passed.		

## Comments: