

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20181713  
Address: 3348 SW JESSIE LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                     | Inspector:   | Outcome: | Date:                  |
|---------------------------------|--------------|----------|------------------------|
| <b>DE - Sidewalk Inspection</b> | Brice Lawson | Passed   | Thursday, May 02, 2019 |

Informational:  
1      Misc      The sidewalk cross slope is less than 2.0 percent.

**Comments:**