

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183264
Address: 833 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Partial	Thursday, May 02, 2019

Partial Correction:

1 Misc

**OK TO COVER WHEN READY: TRENCHED CONDUIT INSIDE BUILDING LINE;
COPPER LEADS CONNECTED TO RE-BAR UFER JUMPERS AT S.E. AND N.E.
CORNERS OF BLDG;**

Comments: