

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20181663
Address: 1805 SW BLACKSTONE PL, LEES SUMMIT, MO 64082
Inspected On: Thursday, May 02, 2019
Inspected By: Jason McRoy
Expiration Date: 6/2/2019 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Jason McRoy	Temporary C of O	Thursday, May 02, 2019

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | 1. self closing hinges at garage entry door are not operating correctly.
2. install ladder at basement egress window.
3. discharge sump min. 36" away from house.
4. clearance from grass to bottom of siding min. 6" a few spots across the back of the house need to be addressed. |
|---|------|---|