

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20180715
Address: 4825 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Friday, May 03, 2019

Corrective Action Required:

1	Misc	-WINDOW WELL SET TOO LOW. SHALL EXTEND WINDOW WELL AND REGRADE AROUND THE WELL TO SLOPE AWAY FROM THE HOUSE
---	------	---

Comments: