

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20183804
Address: 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Thrust Restraint	Ronald Paynter	Passed	Friday, May 03, 2019

Informational:	
1 Misc	Thrust blacks were poured behind 22 degree and 90 degree bends. Straddle block was poured were the water line needs to go below the gas line.
Informational:	
2 Misc	Thrust blocks were poured behind 22 degrees and 90 degrees bends, along with the end of the fire line.

Comments: