

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183200
Address: 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Partial	Monday, May 06, 2019

Partial Correction:

1 Misc

NO ISSUES FOUND ON UNDER-SLAB ELECTRICAL CONDUIT MATERIAL & WORKMANSHIP. G.C. AND E.C. TO ENSURE LAYOUT IS CORRECT. OK TO COVER WHEN READY: **ONE 3" + ONE 1" FROM MEP A143 TO NEAR NORTH WALL -- THEN WEST TO UNIT A128 ALONG WITH ONE 1" FROM E WALL OF A132 WEST IN SAME TRENCH;**

ONE UNIDENTIFIED 2" STUBBED ABOVE GRADE SOUTH OF A143.

Comments: