

Inspection Summary

Permit #: PRRES20172649, Building Permit - Residential

Address: 4801 SW RAINTREE PKWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Steve Robbins	Partial	Tuesday, May 07, 2019

Informational

- 1 It appears that 4 inches of rock has been installed, they were a little short on the 6" of depth so I waited while they dug out some more to achieve the 6" of depth.

Comments: