

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181488
Address: 4060 NE CHAPEL MANOR DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Tuesday, May 07, 2019

Corrective Action Required:

1	Misc	-Driveway not approved on record -Lawn irrigation permit -Install sump pump discharge pipe -Install security strike plate at deck door and nail embedded metal brace into studs -Secure cooktop FMC raceway per code -Anchor columns -Secure PEX water lines at mid-wall height -Lag deck ledger board -Landing at bedroom escape window and ladder
---	------	---

Comments: