

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20173060  
Address: 1705 NE PARKWOOD DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Failed	Tuesday, May 07, 2019

Corrective Action Required:

1	Misc	-Seal exterior wall penetrations -Secure AC whip -Install flat 2x4 at top of garage stair handrail for graspable requirement; since this is a required handrail now, because of the 4 risers. -Install sprak rings for all countertop receptacle boxes recessed more than 1/4" behind backsplash -Deck light&fan not powered -Install breaker lock for out-of-sight water heater -Securely fasten gfci receptacle box below outdoor cam video recorder
---	------	--

Comments: