

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20190113  
Address: 2005 NE BLUESTONE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Wednesday, May 08, 2019

Corrective Action Required:

1 Misc

FRAMING:

-CS-PF walls required at rear dining exterior wall  
\*\*strap header

MECHANICAL:

-Complete installing water heater flue  
\*\*install insulation shield

Comments: