

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20190930  
Address: 410C SE 3RD ST, Unit:106, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                    | Inspector:   | Outcome: | Date:                   |
|--|--------------|----------|-------------------------|
| <b>Occupancy Inspection - Codes Commercial</b> | Mark Harding | Failed   | Wednesday, May 08, 2019 |

Corrective Action Required:

|   |      |   |
|---|------|---|
| 1 | Misc | - Vertical grab bar is over 41" from rear wall.<br>39-41 is approved distance.<br>- install Epoxy paint per plans in restroom.<br><br>recall when complete for inspection |
|---|------|---|

Comments: