

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182860
Address: 697 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mike Copeland	Partial	Thursday, May 09, 2019

Partial Correction:

1	Misc	OK TO COVER WHEN READY GWB BULKHEAD FRAMING & SYSTEMS TO BE ENCLOSED
---	------	--

ALL APPROVED TO DROP EXCEPT RESTROOM. INSTALL COPPER TUBING FOR PRESSURE RELIEF VALVE TO EXTEND TO WITHIN 6" OF FLOOR OR PAN SURFACE.

Comments: