

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20190930
Address: 410C SE 3RD ST, Unit:106, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Thursday, May 09, 2019

Corrective Action Required:

1	Misc	- Vertical grab bar is over 41" from rear wall. 39-41 is approved distance. - install Epoxy paint per plans in restroom.
---	------	--

recall when complete for inspection

Partial Correction:

2	Misc	OCCUPANCY STATUS: OK TO SET UP FOR BUSINESS. STAFFING, TRAINING, FIXTURING, STOCKING OK. NO PUBLIC/CUSTOMERS/PATIENTS PRIOR TO APPROVAL.
---	------	---

Comments: