

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183043
Address: 316 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mike Copeland	Failed	Thursday, May 09, 2019

Corrective Action Required:

1	Misc	-OBTAIN FIRE DEPARTMENT APPROVAL -REPAIR ASPHALT NEXT TO PATIO WHERE BACKFLOW VAULT IS LOCATED -COMPLETE RAIL AT EAST RAMP -PAY EXCISE TAX -PROTECT GLAZING FROM THE INSIDE NEXT TO D.J. STAIRS (CAN INSTALL LISTED PROTECTED FILM OVER WINDOWS THAT ARE REQUIRED TO BE TEMPERED.) -OBTAIN HEALTH DEPARTMENT APPROVAL OKAY TO STOCK AND TRAIN EMPLOYEES
---	------	---

Comments: