

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSITE20190091  
Address: 316 SE DOUGLAS ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:              | Inspector:  | Outcome: | Date:                  |
|--------------------------|---|----------|------------------------|
| <b>DE - Site Visit</b>   | Joe Starlin   | Partial  | Thursday, May 09, 2019 |
| Informational:<br>1 Misc | 3-22-19 Talked with Scott he is getting ready to jackhammer the concrete to get to the water line.  |          |                        |
| Informational:<br>2 Misc | Joe Starlin 03/28/2019 11:42 AM I met with water on site to discuss water valves to shut off for the tie in.  |          |                        |
| Informational:<br>3 Misc | 4-1-19 Talked with Scott he used C900 pipe for under the road. Looks like we are good to go for water tie in on 4-3-19 at 12am.   |          |                        |
| Informational:<br>4 Misc | 4-5-19 Talked with Scott, he has a leak at one of his connections. It appears we will have to do another water shut down to do the repair.  |          |                        |
| Informational:<br>5 Misc | Joe Starlin 04/09/2019 11:18 AM Talked with Scott Briscoe about putting out the door hangers for the water shut down taking place on 4-12-19 on Douglas. I gave him the door hangers and he said they would be put out today just after 11am. |          |                        |
| Informational:<br>6 Misc | 4-23-19 Scott pressurized the fire line at 220psi for two hours and it passed. We then chlorinated the line and it will sit for 24 hours.   |          |                        |
| Informational:<br>7 Misc | 5-9-19 At the commercial final I let the owner know that the only outstanding item I have is asphalt patch needs to be done.  |          |                        |

**Comments:**