

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20182431
Address: 4426 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Plot Plan Inspection	Steve Conrick	Failed	Thursday, May 09, 2019

Comments:

The area around the inlet has silted in and there is rock surrounding the inlet. The rock is being used as a filter, but may need to be removed to get the area to the correct grade. The area needs to be graded to the throat on all sides of the inlet and inlet protection used on sides with no vegetation. (the plat to the NW is lacking proper ESC) 1700 SW Merryman also requires an As-graded plot plan and already has a fence that might make it difficult to grade the area out.