

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20183804
Address: 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|----------------|----------|----------------------|
| DE - Water Line - Coliform Test 1 | Ronald Paynter | Passed | Friday, May 10, 2019 |

Informational:
1 Misc First sample passed coliform and E. coli test done by Keystone Laboratories.
RP 5-10-19

Comments: