

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20180219
Address: 201 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Hydrostatic Test	Ronald Paynter	Passed	Friday, May 10, 2019

Corrective Action Required:

1	Misc	Water line lost 10 PSI during the test. Mike's crew is going to work on the line and reschedule another test next week.
---	------	---

Informational:

2	Misc	Water line held 150 PSI for 2 hrs. RP 5-10-19
---	------	---

Comments: