

Inspection Summary

Permit #: PRSUBD20182996, Development - Subdivision
OAKVIEW STORAGE PHASE II
Address: 1410 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Coliform Test 1 Informational 1	Joe Starlin	Passed	Monday, May 13, 2019
4-25-19 Beemer pulled four samples at four different locations. We will be waiting on lab results.			
Informational 2	The first set of water samples have passed.		
Corrective Action Required 3			
DE - Water Line - Coliform Test 2 Informational 1	Joe Starlin	Passed	Monday, May 13, 2019
5-26-19 Took water samples at four locations on site and drove them to the lab.			
Informational 2	The second set of water samples pulled on 4-26-19 have passed.		

Comments: