

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20182837
Address: 450 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Street - Base Lift	Ronald Paynter	Passed	Tuesday, May 14, 2019

Informational:

1 Misc

J & J Asphalt laid 4 inches of APWA-5 asphalt down for the parking lot base

Informational:

2 Misc

All American Reid-Mix pour 6 inches of 4K KCM MB mix for the base to repair the hole in the handicapped parking spot. Terry is doing the repair work for Spire Gas.

Comments: