

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183588
Address: 2614 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Not Ready	Wednesday, May 15, 2019

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Quick vent not approved under kitchen sink ,use approved air admittance vent.- install Dishwasher- install stove-secure attic access-dbl 2x10 on deck over span.-Final grade, splash blocks, sod, erosion control.- caulk all siding penetrations.- complete sump pump discharge.
---	------	--

Corrective Action Required:

2	Misc	locked no door code and no email about vent . black quicky vents are not appoved just FYI
---	------	---

Comments: