

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183477
Address: 416 NW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	John Borns	Passed	Wednesday, May 15, 2019

**Comments: FOUR PIER HOLES FOUND DUG AT 18" DIAM X 36" DEEP. IF DIMENSIONS MEET THOSE ON
DRAWINGS OK TO POUR WHEN READY.**