

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20184050
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary Sewer - Air Test	John DiMauro	Passed	Wednesday, May 15, 2019

Informational:

1 Misc

On site with the Redford crew testing both sanitary sewer lines 3-A & 3-B

Sanitary Line 3-A:

Line segment from station 2+74.51 to 4+30.70

Starting psi - 4

End psi - 4

Time - 7:34

Test Passed

Line Segment from 4+30.70 to 5+86.54

Starting psi - 4

End psi - 4

Time - 7:34

Test Passed

Line segment from 5+86.54 to 8+16.54

Starting psi - 4

End psi - 4

Time - 7:34

Test Passed

Sanitary Line 3-B:

Line segment from 2+75.64 to 3+06.16

Starting psi - 4

End psi - 3.75

Time - 7:34

Test Passed

Line segment from 3+03.16 to 3+68.45

Starting psi - 4

End psi - 4

Time - 7:34

Test Passed

Line segment from 3+68.45 to 5+91.71

Starting psi - 4

End psi - 4

Time 7:34

Test Passed

Line segment from 5+91.71 to 7+11.79

Starting psi - 4

End psi - 4

Time - 7:34

Test Passed

Comments: