

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20190091
Address: 316 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Street - Repairs	Joe Starlin	Passed	Thursday, May 16, 2019

Informational:

1 Misc

5-13-19 The parking lot asphalt patch has been completed. I did not like the finished product. The surface was not smooth. The patch was done without notifying me and I was told by the owner of the property Pat that the subgrade was soft so they stoped rolling the asphalt. I explained to him that the subgrade was obviously bad and that the patch will fail sooner that is should. He said he was fine with the work that was done.

Comments: